

Official Laboratory Report

Report To: LOIS ELLIOTT GRAHAM R S M S A  
PO BOX 30817  
LANSING MI 48909

**Sample ID: LJ31150**  
**Work Order: 01003460\_02**

System Name/Owner: OTSEGO05060TP004  
Collection Address: 117 E ORLEANS,OSTEGO  
Collected By: MICHAL KOSCIARZ  
Township/Well#/Section: //  
County: Allegan  
Sample Point: TP004  
Water System: Public System Well

WSSN/Pool ID: 05060  
Source: TYPE I  
Site Code:  
Collector: Other  
Date Collected: 10/29/2020 10:55  
Date Received: 10/30/2020 12:54  
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

**Per-And Polyfluorinated Alkyl Substances**

11CI-PF3OUdS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/05/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	11/05/2020	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	11/05/2020	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/05/2020	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/05/2020	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	11/05/2020	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/05/2020	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2058-94-8

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

**Sample ID: LJ31150**

**Work Order: 01003460\_02**

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Allegan County Health Dept  
3255 122nd Street, Suite 200  
Allegan, MI 49010  
269 673-5411**

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane



MICHIGAN DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
DRINKING WATER LABORATORY  
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270  
Lansing, MI 48909  
TEL: (517) 335-8184  
FAX: (517) 335-8562

Official Laboratory Report

Report To: LOIS ELLIOTT GRAHAM R S M S A  
PO BOX 30817  
LANSING MI 48909

Sample ID: LJ31151  
Work Order: 01003460\_03

System Name/Owner: OTSEGO05060TP006  
Collection Address: 117 E ORLEANS, OTSEGO  
Collected By: MICHAL KOSCIARZ  
Township/Well#/Section: //  
County: Allegan  
Sample Point: TP006  
Water System: Public System Well

WSSN/Pool ID: 05060  
Source: TYPE I  
Site Code:  
Collector: Other  
Date Collected: 10/29/2020 10:45  
Date Received: 10/30/2020 12:54  
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/05/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2355-31-9
PFBS	6	ng/L	2	11/05/2020	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	11/05/2020	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/05/2020	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/05/2020	6	EPA 537.1	375-95-1
PFOA	2	ng/L	2	11/05/2020	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/05/2020	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2058-94-8

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

**Sample ID: LJ31151**

**Work Order: 01003460\_03**

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U. S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Allegan County Health Dept  
3255 122nd Street, Suite 200  
Allegan, MI 49010  
269 673-5411**

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: LOIS ELLIOTT GRAHAM R S M S A  
PO BOX 30817  
LANSING MI 48909

Sample ID: **LJ31152**  
Work Order: **01003460\_04**

System Name/Owner: OTSEGO05060TP003  
Collection Address: 117 E ORLEANS, OTSEGO  
Collected By: MICHAL KOSCIARZ  
Township/Well#/Section: //  
County: Allegan  
Sample Point: TP003  
Water System: Public System Well

WSSN/Pool ID: 05060  
Source: TYPE I  
Site Code:  
Collector: Other  
Date Collected: 10/29/2020 10:35  
Date Received: 10/30/2020 12:54  
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/05/2020		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/05/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2355-31-9
PFBS	13	ng/L	2	11/05/2020	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	375-85-9
PFHxA	3	ng/L	2	11/05/2020	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/05/2020	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/05/2020	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	11/05/2020	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/05/2020	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/05/2020		EPA 537.1	2058-94-8

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

**Sample ID: LJ31152**

**Work Order: 01003460\_04**

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Allegan County Health Dept  
3255 122nd Street, Suite 200  
Allegan, MI 49010  
269 673-5411**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane